



PRODUCT

PRODUCT USE INSTRUCTIONS



Ordering code: 007B18

Part number: FNI MPL-508-105-IOT

FNI MPL-508-105-IOT

8xIO-Link,16 DI/DO PNP

IO-Link Master Module User Manual



Contents

Security	5
■ Expected use	5
■ Installation and start-up	5
■ Corrosion resistance	5
■ Dangerous voltage	5
■ General security	6
1 Getting started guide	7
1.1 Module overview	7
1.2 Mechanical connection	8
1.3 Electrical connections	8
1.3.1 Power interface (L-coded)	8
1.3.2 Network interface (D-coded)	9
1.3.3 I/O-port (A-coded)	9
1.3.4 Master module wiring method	10
2 Technical data	11
2.1. Size	11
2.2 Mechanical data	11
2.3 Operating conditions	11
2.4 Electrical data	11
2.5 Network port	12
2.6 Function indicator	12
3 Integrated	16
3.1 Module configuration	16
3.1.1 Module protocol description	16
3.1.2 Agreement modification	16
3.2 Data mapping	17
3.3 PLC integration tutorial	25
3.3.1 Siemens S7-1200 Botu Integration (PN)	25
3.3.2 Omron NX1P2 Sysmac Studio Integrated (EIP)	27
3.3.3 Mitsubishi FX5U Work2 Integrated (CIE)	29

4 IoT configuration	31
4.1 MQTT configuration	31
5 Appendix.....	34
5.1 Materials included	34
5.2 Order code.....	34
4.3 Ordering information	34

■ Expected use

This manual describes as decentralized input and output modules for connecting to an industrial network.

■ Installation and start-up

Precautions!

Installation and start-up may only be performed by trained personnel. A qualified individual is one who is familiar with the installation and operation of the product and has the necessary qualifications to perform such operations. Any damage caused by unauthorized operation or illegal and improper use is not covered by the manufacturer's warranty. The equipment operator is responsible for ensuring that appropriate safety and accident prevention regulations are observed.

■ Corrosion resistance

Precautions!

FNI modules generally have good chemical and oil resistance. When used in corrosive media (e.g. high concentrations of chemicals, oils, lubricants, coolants and other material media (i.e. very low water content), these media must be checked before the corresponding application material compatibility. If a module fails or is damaged due to this corrosive medium, a defect claim cannot be made.

■ Dangerous voltage

Precautions!


Disconnect all power before using the device!

■General security

Debugging and inspection	Fault	Owner/operator obligations	Expected use
Before debugging, read the user manual carefully.	If the defect or equipment failure cannot be corrected, the operation of the equipment must be stopped to avoid damage that may be caused by unauthorized use.	This equipment is an EMC Class A compliant product. This device produces RF noise.	The warranty and limited liability statement provided by the manufacturer does not cover damage caused by: ·Unauthorized tampering ·Improper use operation ·The instructions provided in the user manual explain the use, installation and handling of discrepancies
This system cannot be used in an environment where the safety of personnel depends on the functionality of the equipment.	Only after the housing is fully installed can the intended use be assured.	The owner/operator must take appropriate precautions to use this equipment. This device can only use the power supply that matches this device, and can only connect cables approved for application.	

1. Getting Started Guide

1.1 Module overview



- | | | |
|-----------------------------------|------------------------------------|--------------------------------------|
| 1 Network port 1 status indicator | 9 Port status indicator | 17 IOT network port status indicator |
| 2 Network port 1 | 10 Port 2 | 18 IOT network port |
| 3 Network port 1 status indicator | 11 Port 4 | 19 IOT network port status indicator |
| 4 Module indicator | 12 Port 6 | 20 Power output interface |
| 5 Power input port | 13 Mounting hole | 21 Port 1 |
| 6 Port identification board | 14 Network port 2 status indicator | 22 Port 3 |
| 7 Port status indicator | 15 Network port 2 | 23 Port 5 |
| 8 Port 0 | 16 Network port 2 status indicator | 24 Port 7 |


1.2 Mechanical connection

The modules are connected using 2 M6 bolts and 2 washers.
Isolation pads are available as accessories.


1.3 Electrical connection

1.3. 1 Power interface(L-code)


Power input port definition



Power output port definition



Power port




Pin	Function	Description
1	Us+	+24V(brown)
2	Ua-*	0V(white)
3	Us-	0V(blue)
4	Ua+*	+24V(black)
FE	Functional ground*	FE (yellow green)

Note:

1. If possible, provide sensor/module power supply and actuator power supply separately.
The total current of all modules is <16A, even if the actuator power supply is daisy chained.
2. The FE connection from the housing to the machine must be low impedance and kept as short as possible.


1.3.2 Network interface(D-code)



Pin	Function	
1	Tx+	Send data+
2	Rx+	Receive data+
3	Tx-	Send data-
4	Rx-	Receive data-


Note:
Unused I/O port sockets must be covered with end caps to meet IP67 protection rating

1.3.3 I/O-port(A-code)




Pin	Function
1	+24V (brown) maximum current 1A
2	Input/output (white)
3	0V(blue)
4	Input/output/IOLINK (black)
5	FE(gray)

Normal I/O




- Note:
- 1. Regarding digital sensor input, please follow the input guidance of EN61131-2, Type 2.
 - 2. The maximum output current of each port is 2A. The total module current is 16A.
 - 3. Unused I/O port sockets must be covered with end caps to meet IP67 protection level.

1.3.4 Main station module wiring method




In independent power supply mode, the maximum current of each master station can reach 16A.



In the serial power supply wiring mode, if the rear module needs to be connected to the front module, the cumulative current must not exceed 16A.

2 Technical data

2.1. Size



2.2 Mechanical data

Shell material	Die-cast aluminum housing, pearl nickel plated
Housing rating according to IEC 60529	IP67 (only in plug-in or plug type)
Power interface	L-Code (male and female)
Input port/output port	M12, A-Code (8*Female)
Size(W*H*D)	65mm*222mm*30.5mm
Installation type	2-Through hole mounting
Ground bus accessories	M4
Weight	About 670g

2.3 Operating conditions

Operating temperature	-5°C ~ 70°C
Storage temperature	-25°C ~ 70°C

2.4 Electrical data

Supply voltage	18~30V DC, comply with EN61131-2
voltage fluctuation	<1%
Input current when power supply voltage is 24V	<130mA

2.5 Network port

Port	2 x 10Base-/100Base-Tx
Port connection	M12, D-Code
IEEE 802.3 compliant cable types	Shielded twisted pair, minimum STP CAT 5/STP CAT 5e
Data transfer rate	10/100 M bit/s
Maximum cable length	100m
Flow control	Half working condition/full working condition (IEEE 802.3-PAUSE)

2.6 Function indicator



PT	Green	EtherNet/IP communication protocol
	Yellow	ProfiNet communication protocol
	Blue	EtherCat communication protocol (reserved)
	Ice blue	Modbus TCP communication protocol
	White	CC-Link IE Field basic communication protocol

EtherNet/IP communication protocol module status

LED	Show	Function
MS	Green light is always on	Working status: The equipment is running normally
	Green light flashes 1HZ	Standby: The device is not configured
	Flashing green, red and green alternately	Self-test: The device is undergoing a power-on self-test.
	Flashing red 1HZ	Recoverable faults:
	Red light always on	Unrecoverable failure
	Cosure	US no input voltage
NS	Green light is always on	Connected
	Green light flashes 1HZ	Not connected

	Flashing green and red alternately	Self-test: The device is undergoing a power-on test.
	Red light flashes 1HZ	Connection timeout
	Red light always on	Duplicate IP
	Closure	USNo input voltage or no IP address
US	Green	Input voltage is normal
	Flashing red	Input voltage low (< 18 V)
UA	Green	Output voltage is normal
	Flashing red	Output voltage low (< 18 V)
	Red always on	No output voltage present (< 11 V)

Profinet communication protocol module status

LED	Show	Function
SF	Closure	Working fine
	Flashing red 3s 1HZ	Bus start
	Red always on	System error
BF	Closure	Working fine
	Flashing red 2HZ	No data exchange
	Red always on	No configuration; or low speed physical link; or no physical link
US	Green	Input voltage is normal
	Flashing red	Input voltage low (< 18 V)
UA	Green	Output voltage is normal
	Flashing red	Output voltage low (< 18 V)
	Red always on	No output voltage present (< 11 V)

CC-Link IE Field Basic communication protocol module status


LED	Show	Function
RUN	Green light off	Module not connected
	Green light flashes 2.5HZ	Module has no communication
	Green light flashes 10HZ	Module not configured
	Steady green	Running: The device is running
	Closure	Module disconnected
ERR	Closure	Module disconnected
	Red light always on	Communication error
	Flashing red light	Watchdog timeout
US	Green	Input voltage is normal

	Flashing red	Input voltage low (< 18 V)
UA	Green	Output voltage is normal
	Flashing red	Output voltage low (< 18 V)
	Red always on	No output voltage present (< 11 V)

Modbus TCP communication protocol module status


LED	Show	Function
RUN	Green light off	Module not connected
	Green light flashes 5HZ	Module configured
	Green light flashes 1HZ	Module is prepared but not configured
	Steady green	Running: The device has at least one TCP communication
	Closure	Module not ready
ERR	Closure	Module works fine
	Red light flashes (2HZ)	System error
	Red light always on	Communication error
US	Green	Input voltage is normal
	Flashing red	Input voltage low (< 18 V)
UA	Green	Output voltage is normal
	Flashing red	Output voltage low (< 18 V)
	Red always on	No output voltage present (< 11 V)

I/O port status



LED	State	Function
1	Closure	The status of Pin4 input or output is 0
1	Yellow	The status of Pin4 input or output is 1
1	Red	Port configured as output: Pin4 short circuit
1	Flashing red	Port configured as output: Pin1 short circuit
1	Green	IO Link is connected
1	Flashing green	IO Link not connected
2	Closure	The status of Pin2 input or output is 0

2	Yellow	The status of Pin2 input or output is 1
2	Red	The UA power supply is cut off or the network is disconnected or Pin2 is short-circuited.
2	Flashing red	Pin1 short circuit



Network port status

LED	State	Function
ACT	Closure	Bus rate: 10Mbit/s
	Yellow	Bus rate: 100Mbit/s
LK1 IN (ECT IN)	Flashing green	Data transfer in progress
LK2 IN (ECT OUT)	Flashing green	Data transfer in progress

3 Integrated

3.1 Module configuration

3.1.1 Module protocol description

LED indicator light PT color indicates the current protocol

Serial number	Communication protocol	PT
1	ETHERNET/IP	Green light
2	PROFINET	Orange light
3	CIEBS	White


When the module is shipped from the factory, the default IP of the IOT network port is 192.168.0.2. Through this URL, you can enter the WEB interface for configuration operations.

Login account: admin

Login password: admin

3.1.2 Agreement modification

1、Log in to the web interface, click Advanced to enter the advanced interface and select protocol switching.



2、Select the desired protocol and click Confirm to wait for the switch to complete.

PROFINET ▼	Confirm	Status: Not currently switching
------------	---------	---------------------------------

3.2 Data mapping

EIP communication protocol process output data									
Byte	Function description								
	Function description	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
0	Standard IO output	Port7 Pin4	Port6 Pin4	Port5 Pin4	Port4 Pin4	Port3 Pin4	Port2 Pin4	Port1 Pin4	Port0 Pin4
1	0=off 1=on	Port7 Pin2	Port6 Pin2	Port5 Pin2	Port4 Pin2	Port3 Pin2	Port2 Pin2	Port1 Pin2	Port0 Pin2
2 ~ 5	Reserve								
6 ~ 37	Port 0 process output data								
38 ~ 69	Port 1 process output data								
70 ~ 101	Port 2 process output data								
102 ~ 133	Port 3 process output data								
134 ~ 165	Port 4 process output data								
166 ~ 197	Port 5 process output data								
198 ~ 229	Port 6 process output data								
230 ~ 261	Port 7 process output data								

EIP communication protocol process input data									
Byte	Function description								
	Function description	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
0	Standard IO input 0=no signal 1=There is signal	Port7 Pin4	Port6 Pin4	Port5 Pin4	Port4 Pin4	Port3 Pin4	Port2 Pin4	Port1 Pin4	Port0 Pin4
1	Standard IO input 0=no signal 1=There is signal	Port7 Pin2	Port6 Pin2	Port5 Pin2	Port4 Pin2	Port3 Pin2	Port2 Pin2	Port1 Pin2	Port0 Pin2
2	Pin4 short circuit 0=no short circuit 1=There is a short circuit	Port7 Pin4	Port6 Pin4	Port5 Pin4	Port4 Pin4	Port3 Pin4	Port2 Pin4	Port1 Pin4	Port0 Pin4
3	Pin2 short circuit 0=no short circuit 1=There is a short circuit	Port7 Pin2	Port6 Pin2	Port5 Pin2	Port4 Pin2	Port3 Pin2	Port2 Pin2	Port1 Pin2	Port0 Pin2
4	Pin1 short circuit 0=no signal 1=There is signal	Port7 Pin1	Port6 Pin1	Port5 Pin1	Port4 Pin1	Port3 Pin1	Port2 Pin1	Port1 Pin1	Port0 Pin1
5	IOLink communication status 0=not connected 1=Connected	Port7	Port6	Port5	Port4	Port3	Port2	Port1	Port0
6	IOLink PD valid 0=disabled 1=enable	Port7	Port6	Port5	Port4	Port3	Port2	Port1	Port0
7	Module status	-	-	-	Us overvol tage	Ua overvol tage	Overhe at	Us Underv oltage	Ua Underv oltage
8 ~ 9	Reserve								
10 ~ 41	Port 0 process input data								
42 ~ 73	Port 1 process input data								
74 ~ 105	Port 2 process input data								
106 ~ 137	Port 3 process input data								
138 ~ 169	Port 4 process input data								
170 ~ 201	Port 5 process input data								
202 ~ 233	Port 6 process input data								
234 ~ 265	Port 7 process input data								

EIP communication protocol configuration data									
Variable	Function description								
	Function description	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
Word	Pin4 Function 00=Normally open input 01=Normally closed input 10=output 11=IOLink	Port3		Port2		Port1		Port0	
		Bit15	Bit14	Bit13	Bit12	Bit11	Bit10	Bit9	Bit8
		Port7		Port6		Port5		Port4	
Word	Pin2 Function 00=Normally open input 01=Normally closed input 10=output	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
		Port3		Port2		Port1		Port0	
		Bit15	Bit14	Bit13	Bit12	Bit11	Bit10	Bit9	Bit8
		Port7		Port6		Port5		Port4	
Word	Pin4 SafeState 00 = remain at 0 01 = remain at 1 10 = keep the last value	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
		Port3		Port2		Port1		Port0	
		Bit15	Bit14	Bit13	Bit12	Bit11	Bit10	Bit9	Bit8
		Port7		Port6		Port5		Port4	
Word	Pin2 SafeState 00 = remain at 0 01 = remain at 1 10 = keep the last value	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
		Port3		Port2		Port1		Port0	
		Bit15	Bit14	Bit13	Bit12	Bit11	Bit10	Bit9	Bit8
		Port7		Port6		Port5		Port4	
Byte	Port0 configuration*	(1byte) IOLink CycleTime (1byte) Validation Type (2bytes) Vendor ID1~ID2 (3bytes) Device ID1~ID3 (16bytes) Serial Number1~16 (1byte) Parameter Server							
Byte	Port1 configuration*	(same as above)							
Byte	Port2 configuration*	(same as above)							
Byte	Port3 configuration*	(same as above)							
Byte	Port4 configuration*	(same as above)							

Byte	Port5 configuration*	(same as above)
Byte	Port6 configuration*	(same as above)
Byte	Port7 configuration*	(same as above)

Note:

When using Omron and Delta PLC, the configuration data is set in the module properties, and AB PLC is set in the mapping data.

*Port configuration parameter description:

A. (1byte) IOLink CycleTime cycle time setting:

This parameter can be used for IO-Link communication speed. Using multipliers and time base calculations, the IO-Link cycle time can be increased.

The time base is described in the table below. The multiplier is entered in decimal form from 0...63.

Bit								Description
7	6	5	4	3	2	1	0	
Time base		Multiplier						Bit 0 to 5: Multiplier These bits contain a 6-bit multiplier for the calculation of MasterCycleTime or MinCycleTime. Permissible values for the multiplier are 0 to 63.
								Bit 6 to 7: Time Base These bits specify the time base for the calculation of MasterCycleTime or WincycleTime.

Possible values for MasterCycleTime and MiniCycleTime

Time base encoding	Time base value	Calculation	Cycle time
00	0.1ms	Multiplier x time base	0.4 ms to 6.3 m
01	0.4ms	6.4 ms + multppler x time base	6.4 ms to 31.6 ms
10	1.6ms	32,0 ms + multiplier x time base	32.0 ms to 132.8 ms
11	Reserved	Reserved	Reserved
NOTE: The value 0.4 results from the minimum possible transmission time according to A.3.7			

B、(1byte) Validation Type Validation type setting:

(Value=0) No verification: Verification is disabled and every device will be accepted.

(Value=1) Compatibility: Compare the manufacturer ID/device ID with the IO-Link device data.

(Value=2) Identity: Compares Manufacturer ID/Device ID/Serial Number with IO-Link

device data. IO-Link communication only starts if there is a match.

C. (2bytes) Vendor ID1~ID2 manufacturer ID

D. (3bytes) Device ID1~ID3 device ID

E. (16bytes) Serial Number1~16 serial number

F. (1byte) Parameter Server parameter server (reserved)

ProfiNet communication protocol process monitoring data									
Module	Function description								
	State illustrate	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
Actuator shutdown pin 2	Pin2 port short circuit 0=Normal 1=short circuit	Port 7 Pin2	Port6 Pin42	Port5 Pin2	Port4 Pin2	Port3 Pin2	Port2 Pin2	Port1 Pin2	Port0 Pin2
Actuator shutdown pin 4	Pin4 port short circuit 0=Normal 1=short circuit	Port 7 Pin4	Port6 Pin4	Port5 Pin4	Port4 Pin4	Port3 Pin4	Port2 Pin4	Port1 Pin4	Port0 Pin4
Sensor supply short circuit	Pin1 port short circuit 0=Normal 1=short circuit	Port 7 Pin1	Port6 Pin1	Port5 Pin1	Port4 Pin1	Port3 Pin1	Port2 Pin1	Port1 Pin1	Port0 Pin1
Device Status	Module state	-	-	-	Usover voltage	Uaover voltage	Overheat	UsUndervoltage	UaUndervoltage
IO-Link communication state	Communication status 0=Disconnect 1=Connect	Port 7	Port6	Port5	Port4	Port3	Port2	Port1	Port0
IO-Link PD Valid	IO-Link PD valid 0=disabled 1=enable	Port 7	Port6	Port5	Port4	Port3	Port2	Port1	Port0

Standard I/O	Standard IO auxiliary slot	(match Input Pin2, Pin4, use Output Pin2, Pin4)
--------------	----------------------------	---

CCIEBS communication protocol process output data									
Byte	Function description								
	Function description	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
RY (Maximum 256Bit)	Standard IO output 0=off 1=on	Port7 Pin4	Port6 Pin4	Port5 Pin4	Port4 Pin4	Port3 Pin4	Port2 Pin4	Port1 Pin4	Port0 Pin4
		Port7 Pin2	Port6 Pin2	Port5 Pin2	Port4 Pin2	Port3 Pin2	Port2 Pin2	Port1 Pin2	Port0 Pin2
	(The rest of the points are reserved)								
RWW (Maximum 256Byte)	Port 0 process output data (32Byte)								
	Port 1 process output data (32Byte)								
	Port 2 process output data (32Byte)								
	Port 3 process output data (32Byte)								
	Port 4 process output data (32Byte)								
	Port 5 process output data (32Byte)								
	Port 6 process output data (32Byte)								
	Port 7 process output data (32Byte)								

CCIEBS communication protocol process input data									
Byte	Function description								
	Function description	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
RX (Maximum 256Bit)	Standard IO input 0=no signal 1=There is signal	Port7 Pin4	Port6 Pin4	Port5 Pin4	Port4 Pin4	Port3 Pin4	Port2 Pin4	Port1 Pin4	Port0 Pin4
	Standard IO input 0=no signal 1=There is signal	Port7 Pin2	Port6 Pin2	Port5 Pin2	Port4 Pin2	Port3 Pin2	Port2 Pin2	Port1 Pin2	Port0 Pin2
	Pin4 short circuit 0=no short circuit 1=There is a short circuit	Port7 Pin4	Port6 Pin4	Port5 Pin4	Port4 Pin4	Port3 Pin4	Port2 Pin4	Port1 Pin4	Port0 Pin4
	Pin2 short circuit 0=no short circuit 1=There is a short circuit	Port7 Pin2	Port6 Pin2	Port5 Pin2	Port4 Pin2	Port3 Pin2	Port2 Pin2	Port1 Pin2	Port0 Pin2
	Pin1 short circuit 0=no short circuit 1=There is a short circuit	Port7 Pin1	Port6 Pin1	Port5 Pin1	Port4 Pin1	Port3 Pin1	Port2 Pin1	Port1 Pin1	Port0 Pin1
	IOLink communication status 0=not connected 1=Connected	Port7	Port6	Port5	Port4	Port3	Port2	Port1	Port0
	IOLink PD valid 0=disabled	Port7	Port6	Port5	Port4	Port3	Port2	Port1	Port0

	1=enable								
	Module status	-	-	-	Usover voltage	Uaover voltage	Overheat	UsUndervoltage	UaUndervoltage
	(The rest of the points are reserved)								
RWR (Maximum 256Byte)	Port 0 process input data (32Byte)								
	Port 1 process input data (32Byte)								
	Port 2 process input data (32Byte)								
	Port 3 process input data (32Byte)								
	Port 4 process input data (32Byte)								
	Port 5 process input data (32Byte)								
	Port 6 process input data (32Byte)								
	Port 7 process input data (32Byte)								

Note:


1. Please set the CCIEBS master port function in the FAS IOLink Tool software.
2. Points of 64 occupy 1 station, and the slave station connected to each port uses 4 words of points.
3. Points 128 occupy 2 stations, and the slave station connected to each port uses 8 words of points.
4. Points 192 occupy 3 stations, and the slave station connected to each port uses 12 words.
5. Points 256 occupy 4 stations, and the slave station connected to each port uses 16 words of points.
6. Refer to Chapter 5.1.3 for point setting. The CCIEBS master station occupies 4 stations by default.

3.3 PLC integration tutorial


(The module communication protocol should be set before configuring the module, see 5.1.1 for details)

3.3.1 Siemens S7-1200 Botu Integration (PN)


- 1、Install GSD file




2. In PLC---Device Configuration---Network View---Hardware Catalog, select the module and drag it in, click "Unassigned", and select the PLC to be connected;



3. Double-click the module to enter the configuration.
 - (1) Slot function configuration: Select the required data in the hardware catalog--Module and drag it into the slot in the device overview window;
 - (2) Module port function configuration: Click the module icon, select "General", then click slot 1 to configure the port function.




(3) Module function configuration: Click the module icon, select "General", then click slot 0 to configure the module function.




(4) After the configuration is completed, click Download in the configuration view.

4. Assign module PN name: PLC switches to online state, select "Ungrouped Devices" --- Click on the module name---Select Online and Diagnostic ---Function-----Assign PROFINET device name--- -Select the module to be assigned in the list (should be selected based on the physical MAC)--- Click "Assign Name" to complete the configuration!




3.3.2 Omron NX1P2 Sysmac Studio integration (EIP)


1、Install the EDS file: Tools---ETHERNET/IP connection settings---double-click the PLC in the window---right-click the blank space of the toolbox on the right and select "Show EDS Library", click "Install" in the pop-up window, and select EDS file installation.



2、Create a module: Click "+" in the toolbox window, fill in the module IP address, model name, and version, click "Add" below, and the module creation is completed;



3、Configure the module: right-click the module--select "Edit"---configure the parameters according to actual needs and click OK after completing the corresponding values.




4、Create variable association:


(1) Programming--Data--Global variables create two arrays, output 262 bytes and input 266 bytes. The corresponding input and output should be configured in the network exposure;

EtherNet/IP Device List Built-in EtherNet/IP Connection Settings Global Variables								
Group Filter (No group)								
Name	Data Type	Initial Value	AT	Retain	Constant	Network Publish	Comment	
IN	ARRAY[0..265] OF BYTE			☐	☐	Publish Only		
OUT	ARRAY[0..261] OF BYTE			☐	☐	Publish Only		

(2) In the built-in ETHERNET/IP port setting window--select the first icon (label) on the left---click "Register All".




(3) In the built-in ETHERNET/IP port setting window--select the second icon on the left (connection)---click "+", select the previously configured module for the target device, select EXCLUSIVE Owner for the IO type, select the corresponding input and output, the target variable must be filled in 101,100; then select the corresponding starting variable, and go online after completion. Select "Transfer to controller" and the configuration is complete!




3.3.3 Mitsubishi FX5U Work3 Integrated (CIE)


1. Install the CCSP file: First open GX WORKS 3-Tools-Configuration File Management-Login-CSPP file (the project must be closed to import the file).




2. Click Project-Parameters-FX5UCPU-Module Parameters-Ethernet Port on the left, Basic Settings-Self Node Settings. Set own node IP.




3. Click CC-Link IEF Basic Settings-select whether to use CC-Link IEF Basic-click Use.



4. Click CC-Link IEF Basic settings-select network configuration settings-detailed settings;



5. Automatic detection of connected devices - occupies 4 stations, IP address is set using DIP switches - reflects settings and closes.



6.To refresh the target, select the specified device - device name M - assign the device address - apply, and the configuration is completed!

Setting Item

Link Side						CPU Side				
Device Name	Points	Start	End		Target	Device Name	Points	Start	End	
RT	256	00000	000FF	↔	Specif	M	256	256	511	
RT	256	00000	000FF	↔	Specif	M	256	0	255	
RWr	128	00000	0007F	↔	Specif	D	128	128	255	
RWw	128	00000	0007F	↔	Specif	D	128	0	127	

Explanation

Set the device start No. of CPU device for Refresh range.
[Setting range]
Use the device setting of CPU parameter.

Check


Restore the Default Settings

Apply

4.IOT configuration

4.1 MQTT configuration

1. After entering the homepage, click on the configuration interface and select MQTT configuration:



2.You can see MQTT related configuration content in the MQTT configuration interface:

The screenshot shows the MQTT Configuration interface. It contains the following fields and controls:

- Start: ☒
- Server Addresses: 192.168.0.100
- Port: 1883
- Client ID: 007B18 F87A39B020BF
- Publish Topic Quality of Service: QoS0
- Subdevice Topic Quality of Service: QoS0
- Whether the Topic Server Retains: ☐
- Publishing Interval: 3
- Username: User
- Password: *****
- Enable password: ☐
- Message send/receive time interval: 60
- Auto-reconnect interval: 5
- Save button

3.Fill in the MQTT server information according to the actual situation (only supports IPV4) and check the start button and click Save to complete the configuration of MQTT related content:

4. MQTT related topics:

/client/{cid}/master/0/PD	{ "InputPin2":[254], "InputPin4":[254], "OutPin2":[254], "OutPin4":[254], "ASPin2":[254], "ASPin4":[254], "SensorSupplyShortCircuit":[254], "DeviceStatus":[254], "IolinkState":[254] }	Master station PD data
/client/{cid}/master/0/info	{ "device_ID" : 1233, "HW_version" : "testHWversion", "FW_version": "testFWversion", "IOT_ip": "192.168.1.2", "IOT_subnet_mask": "255.255.255.0", "IOT_gateway": "255.255.255.0", "master_BUS": "PNET", "Iolink_version": "v1.13", "master_uptime": 123456 }	Main site information
/client/{cid}/master/0/event	{ "port_id": 1, "instance": 2, "mode": 3, "type": 1, "valid": true, "local": false, "description": "test event" }	Event notifications from the main site
/client/{cid}/master/0/status	{ "Masterstatus": "online" }	Communication status between master station and PLC
/client/{cid}/master/0/extern/read/request	{ "errcor_code": 0, "port_id": 1, "index": 24, "subIndex": 0 }	Master site expansion data read request
/client/{cid}/master/0/PDO/request	{ "OutPin4": [254], "OutPin2": [254], }	Master station PDO data
/client/{cid}/master/0/PDO/response	{ "errcor_code": 0 }	
/client/{cid}/master/0/extern/read/response	{ "errcor_code": 0, "port_id": 1, "index": 24, "subIndex": 0, "data": [10, 12] }	Master station extended data read response

/client/{cid}/master/0/extern/write/request	{ "port_id": 1, "index":24, "subIndex":0, "data":[10 , 12] }	Main site expansion data write request
/client/{cid}/master/0/extern/write/response	{ "errcor_code":0, "port_id": 1, "index":24, "subIndex":0 }	Master station extended data write response
/client/{cid}/port/0/PDO	{ "errcor_code":0, "valid":1, "len":2, "data":[10 , 12] }	Output data from the station
/client/{cid}/port/0/PDI	{ "errcor_code":0, "len":2, "valid":1 , "data":[10 , 12] }	Input data from station
/client/{cid}/port/0/info	{ "port_id":1, "product_ID" : 1233, "vendor_name" : "FAS", "vendor_text" : "FASDev", "HW_version" : "testPortHWversion", "FW_version": "testPortFWversion", "serial_number": "FAS123456" }	Version information
/client/{cid}/port/0/event		Slave event
/client/{cid}/port/0/status	{ "port_id": 1, "status": 2 }	Slave status
/client/{cid}/port/0/extern/ISDU_read/request		Slave expansion data read request
/client/{cid}/port/0/extern/ISDU_read/response		Slave expansion data read response
/client/{cid}/port/0/extern/ISDU_write/request		Slave expansion data write request
/client/{cid}/port/0/extern/ISDU_write/request		Slave station extended data write response


Default cid composition: product model + IIOT network port mac
eg:001B01_123456ABCDEF

5 Appendix

5.1 Materials included

- FNI MPL contains the following parts
- I/O-Block
- 4 blind plugs M12
- Ground bus
- Thread M4x6
- 20 tags

5.2 Order code



4.3 Ordering information

Product ordering code	Order code
FNI MPL-508-105-IOT	007B18

■ High Quality Product / Sincere Service



경기도 성남시 중원구 사기막골로 124
SKn테크노파크 메가동 303호

E-mail: sales@creken.com www.creken.com



FAS / Factory Automation Solution
No. 33 Liuqiao Road, Shangjie Town, Minhou County, Fujian Province
www.faselec.com